



Product Service

# CERTIFICATE

No. Z2 104598 0024 Rev. 00

**Holder of Certificate:** **Mysolar Manufacturing (Shanghai)Co.,Ltd.**  
Room 505-A, Fl 5th, No.507, Wuning Rd, Putuo District  
200063 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262601201-00

**Valid until:** 2030-10-10

**Date,** 2026-02-02

( Zhulin Zhang )

# CERTIFICATE

No. Z2 104598 0024 Rev. 00

## Model(s):

MSxxxN-HJTG, xxx=670-740 in steps of 5  
MSxxxNB-HJTG, xxx=610-675 in steps of 5  
MSxxxNA-HJTG, xxx=550-610 in steps of 5  
MSxxxNE-HJTG, xxx=490-540 in steps of 5  
MSxxxN-HJTG, xxx=670-740 in steps of 5  
MSxxxNB-HJTG, xxx=610-670 in steps of 5  
MSxxxNF-HJTG, xxx=550-605 in steps of 5  
MSxxxNE-HJTG, xxx=490-535 in steps of 5  
MSxxxN-HJTGB, xxx=690-755 in steps of 5  
MSxxxNB-HJTGB, xxx=610-685 in steps of 5  
MSxxxNF-HJTGB, xxx=550-620 in steps of 5  
MSxxxNE-HJTGB, xxx=490-550 in steps of 5  
MSxxxN-DHBG, xxx=680-730 in steps of 5  
MSxxxNB-DHBG, xxx=615-665 in steps of 5  
MSxxxNF-DHBG, xxx=550-600 in steps of 5  
MSxxxNE-DHBG, xxx=490-540 in steps of 5  
MSxxxN-DHBGA, xxx=585-640 in steps of 5  
MSxxxNB-DHBGA, xxx=530-585 in steps of 5  
MSxxxNF-DHBGA, xxx=480-535 in steps of 5  
MSxxxNE-DHBGA, xxx=425-480 in steps of 5  
MSxxxND-DHBA, xxx=595-655 in steps of 5  
MSxxxNC-DHBA, xxx=555-615 in steps of 5  
MSxxxN-DHBA, xxx=495-555 in steps of 5  
MSxxxNB-DHBA, xxx=450-510 in steps of 5  
MSxxxNF-DHBA, xxx=410-470 in steps of 5  
MSxxxNE-DHBA, xxx=365-425 in steps of 5  
xxx is standing for rated output power at STC

## Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute Co., Ltd. No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

## Tested according to:

IEC 61215-1:2021  
IEC 61215-1-1:2021  
IEC 61215-2:2021  
IEC 61730-1:2023  
IEC 61730-2:2023